

---

**From:** [REDACTED]  
**To:** [REDACTED]  
**Sent:** 7/13/2021 9:39:18 PM  
**Subject:** FINAL: HAWC AWARENESS

Notice: This message is being sent from an external partner who is authorized to send email on PG&E's behalf.

\*\*\*\*\*

Name: Dixie, Start Date Time: 07/12/21, 1715, City: Oroville, County: Butte, Division: North Valley, Street: Highway 70 at Cresta Dam, FIA: 248, Tier: 3, Media Aware: No, Max Customers Impacted: 3, Assets Potentially Impacted: Cresta Dam, Caribou-Table Mtn 230 kV, Bucks Creek 1101, Rock Creek-Poe 230kV, Bucks Creek-Rock Creek-Cresta 230kV, Caribou-Palermo 115kV, Status: Ground crew have made access to the fire and are completing containment lines. Fire remains at 2 acres. Bucks Creek 1101 de-energized for safety at the request of firefighters affecting 3 customers (OIS #1403761). Final report unless conditions change significantly.